


BALLABS CERTIFIED TEST REPORT NO.: 20490.0 DATE 05/10/18  
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO  
DESCRIPTION: GEN7 V18 LED 4" TALL HEATSINK 4" RND ADJ DOWNLIGHT @ 0 TILT  
ACRYLIC WIDE TIR OPTIC & 4" ASYM TRIM w/ ANGLED SOLITE LENS  
ADVANCE # XI050C140V054DSM5 @ 1220mA  
CATALOG NBR: 4AR-L40/835-DIM-UNV-A-W-OF-WH (0 DEGREE TILT)  
LAMP TYPE : BXRE-35E4000

0 DEGREE PLANE CONTAINS MAXIMUM CANDLEPOWER



*[Handwritten signature]*

**NVLAP**<sup>®</sup>  
TESTING

NVLAP LAB CODE 200921-0

LUMEN SUMMARY							
ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	1691.	NA.	83.2	90-120	0.	NA.	.0
0- 40	1815.	NA.	89.3	90-130	0.	NA.	.0
0- 60	1972.	NA.	97.0	90-150	0.	NA.	.0
0- 90	2033.	NA.	100.0	90-180	0.	NA.	.0
TOTAL LUMINAIRE =				0-180	2033.	NA.	100.0

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

BALLABS CERTIFIED TEST REPORT NO.: 20490.0 DATE 05/10/18  
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO  
 DESCRIPTION: GEN7 V18 LED 4" TALL HEATSINK 4" RND ADJ DOWNLIGHT @ 0 TILT  
 ACRYLIC WIDE TIR OPTIC & 4" ASYM TRIM w/ ANGLED SOLITE LENS  
 ADVANCE # XI050C140V054DSM5 @ 1220mA  
 CATALOG NBR: 4AR-L40/835-DIM-UNV-A-W-OF-WH (0 DEGREE TILT)  
 LAMP TYPE : BXRE-35E4000

CANDLEPOWER DISTRIBUTION  
 0 DEGREE PLANE CONTAINS MAXIMUM CANDLEPOWER

VERT	HORIZONTAL									LUMENS		
	.0	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0	FRONT	BACK	TOTAL
0	5164.	5164.	5164.	5164.	5164.	5164.	5164.	5164.	5164.			
5	4676.	4671.	4758.	4823.	4944.	5056.	5129.	5169.	5208.	226.6	244.0	470.6
10	3842.	3804.	3922.	4046.	4235.	4528.	4610.	4718.	4724.			
15	2587.	2539.	2648.	2801.	3069.	3290.	3490.	3728.	3735.	378.5	497.4	875.9
20	1261.	1282.	1306.	1405.	1572.	1874.	2122.	2245.	2342.			
25	566.	497.	513.	555.	719.	812.	985.	1116.	1155.	121.7	223.1	344.8
30	226.	219.	223.	242.	291.	376.	481.	544.	555.			
35	124.	121.	130.	144.	172.	219.	272.	301.	333.	41.7	81.6	123.3
40	95.	98.	105.	119.	138.	158.	180.	193.	191.			
45	88.	92.	100.	110.	125.	127.	128.	126.	124.	39.1	49.0	88.1
50	87.	88.	94.	102.	109.	105.	92.	88.	83.			
55	83.	86.	86.	91.	87.	76.	66.	59.	54.	39.5	30.2	69.7
60	78.	80.	76.	72.	62.	49.	40.	31.	28.			
65	71.	70.	64.	55.	43.	29.	21.	13.	10.	31.0	10.6	41.6
70	54.	56.	49.	39.	24.	16.	7.	6.	7.			
75	38.	37.	32.	23.	12.	5.	4.	4.	4.	15.9	2.3	18.1
80	21.	18.	16.	7.	2.	2.	0.	0.	0.			
85	1.	2.	0.	0.	0.	0.	0.	0.	0.	.7	.0	.7
90	0.	0.	0.	0.	0.	0.	0.	0.	0.			

USE .333 FT. AS LENGTH AND .333 FT. AS WIDTH

BALLABS CERTIFIED TEST REPORT NO.: 20490.0 DATE 05/10/18  
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO  
 DESCRIPTION: GEN7 V18 LED 4" TALL HEATSINK 4" RND ADJ DOWNLIGHT @ 0 TILT  
 ACRYLIC WIDE TIR OPTIC & 4" ASYM TRIM w/ ANGLED SOLITE LENS  
 ADVANCE # XI050C140V054DSM5 @ 1220mA  
 CATALOG NBR: 4AR-L40/835-DIM-UNV-A-W-OF-WH (0 DEGREE TILT)  
 LAMP TYPE : BXRE-35E4000

# ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80				.70				.50				.30			.10		.00
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00
RCR																		
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1	1.15	1.12	1.10	1.08	1.12	1.10	1.08	1.06	1.06	1.05	1.03	1.02	1.01	1.00	.99	.98	.97	.96
2	1.09	1.05	1.01	.98	1.07	1.03	1.00	.97	1.00	.98	.95	.97	.95	.93	.95	.93	.91	.90
3	1.05	1.00	.95	.92	1.03	.98	.94	.91	.96	.92	.90	.93	.91	.88	.91	.89	.87	.86
4	1.01	.94	.89	.86	.99	.93	.89	.85	.91	.87	.84	.89	.86	.83	.87	.85	.82	.81
5	.97	.89	.84	.81	.95	.88	.84	.80	.87	.83	.80	.85	.82	.79	.84	.81	.78	.77
6	.93	.86	.81	.77	.92	.85	.80	.77	.83	.79	.76	.82	.78	.76	.81	.78	.75	.74
7	.90	.82	.77	.73	.88	.81	.77	.73	.80	.76	.73	.79	.75	.72	.78	.75	.72	.71
8	.86	.78	.73	.70	.85	.78	.73	.70	.77	.73	.69	.76	.72	.69	.75	.71	.69	.68
9	.83	.75	.70	.67	.82	.74	.70	.66	.73	.69	.66	.73	.69	.66	.72	.68	.66	.65
10	.80	.71	.66	.63	.79	.71	.66	.63	.70	.66	.63	.69	.66	.63	.69	.65	.63	.61

TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20490.0 DATE 05/10/18  
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO  
DESCRIPTION: GEN7 V18 LED 4" TALL HEATSINK 4" RND ADJ DOWNLIGHT @ 0 TILT  
ACRYLIC WIDE TIR OPTIC & 4" ASYM TRIM w/ ANGLED SOLITE LENS  
ADVANCE # XI050C140V054DSM5 @ 1220mA  
CATALOG NBR: 4AR-L40/835-DIM-UNV-A-W-OF-WH (0 DEGREE TILT)  
LAMP TYPE : BXRE-35E4000

\*\*\*\*\*

ELECTRICAL CHARACTERISTICS 119.98V .4063A 48.5980W

LUMINOUS EFFICACY (LUMENS / WATTS) = 41.8

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS  
UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08

