EXIT FIELDSELECT

INSTALLATION INSTRUCTIONS



IMPORTANT:

When re-lamping, only use lamps specified in the exit sign. Using other lamp types may result in damage to the unit or unsafe conditions.

Battery in this unit may not be fully charged. After electricity is hooked up to unit, let the battery charge for at least 24 hours. Normal operation of this unit should then take effect.



IMPORTANT SAFEGUARDS


When using electrical equipment, basic safety precautions should always be followed including the following:

READ AND FOLLOW ALL SAFETY INSTRUCTIONS

- Do not use outdoors.
- Do not mount near gas or electric heaters.
- Equipment should be mounted in locations and at heights where it will not be subjected to tampering by unauthorized personnel.
- The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition.
- Do not use this equipment for other than its intended use.
- Before wiring to power supply, turn off electricity at fuse or circuit breaker.
- Consult local building code for approved wiring and installation.
- Installation and servicing should be performed by qualified personnel.

Ceiling and End Mount Installation:

- 1. Remove EXIT stencil from housing, set aside.
- 2. Place screws (provided) in holes on the canopy.
- 3. Remove the desired mounting hole plug located on the frame of the sign. For ceiling mount, hole plug will be located on the top of the housing. For wall mount, hole plug will be located on the side of the housing.
- 4. Place canopy tab through the mounting hole of the housing until the flat portion of the canopy is touching the housing frame. Lock the canopy into place by sliding the canopy, without turning, toward smaller end of the mounting hole until the tab is fully engaged and locked into place. Once canopy is in the locked position there will not be any side-to-side movement of the canopy.
- 5. Route EXIT input wires through canopy and through metal mounting plate.
- 6. Make wiring connection. For 120V, use black and white wires. And for 277V, use red and white wires. WARNING: Properly insulate the unused lead with a wire nut (provided) or other approved means.
- 7. Push wire connections into the J-Box. Secure mounting plate to junction box (hardware not included).
- 8. Secure the canopy to the steel mounting plate with screws installed in step 2.
- 9. Remove proper chevron(s) as required. When removing chevrons it may be helpful to remove the color diffuser panel to allow easier access to the chevrons. If removing color diffuser panel it is important to remember to reinstall the diffuser panel, securing with diffuser retention caps once chevron(s) have been removed.




EXIT FIELDSELECT

INSTALLATION INSTRUCTIONS

- 10. Connect battery only after continuous AC power can be provided to the unit.
- **11**. Secure face plate(s) to the housing.
- **12**. Apply continuous AC power and press"TEST" button to check operation. See operation (battery back-up) for testing procedures.

WIRING DIAGRAMS:



AC ONLY

NOTE: Properly insulate the unused lead with a wire nut or other approved means.

WARNING: Unused wires must be capped using enclosed wire nuts.

Wall Mount Installation

- 1. Remove EXIT stencil from housing, set aside.
- 2. Drill or knock out appropriate knockouts on backplate to fit junction box mounting points.
- 3. Drill or knock out center hole in backplate for EXIT supply wire leads.
- 4. Route EXIT input wires through center hole of the backplate and make wiring connection. For 120V, use black and white wires. And for 277V, use red and white wires.
- 5. Secure backplate to junction box (hardware not included).
- 6. Connect battery only after continuous AC power can be provided to the unit.
- Remove proper chevron(s) as required. When removing chevrons it may be helpful to remove the color
 diffuser panel to allow easier access to the chevrons. If removing color diffuser panel it is important to
 remember to reinstall the diffuser panel, securing with diffuser retention caps once chevron(s) have been
 removed.
- Apply continuous AC power and press"TEST" button to check operation. See operation (battery back-up) for testing procedures.

EXIT FIELDSELECT

INSTALLATION INSTRUCTIONS

RED-to-Green Conversion:

- Remove the faceplate(s) from the unit's housing.
- Gently pop out the red diffuser lens from the faceplate(s). Replace the green diffuser lens onto the faceplate(s).
- Toggle the dip switch from R to G on the RED/GREEN switchable LED board. 3.
- Replace the faceplate(s) no the housing to finish installation.

Single-to-Double Face Conversion:

- Remove the faceplate from the unit's housing.
- Remove the backplate by pushing out the two locking clips on the inside of the unit's housing.
- Attach the two EXIT faceplates to the housing to complete the conversion.

OPERATION (Battery Backup):

- Apply AC power to the unit. The LED Indicator should turn RED.
- After the battery has been left to charge for 24 hours, test the unit by pushing the switch. The LED indicator turns OFF and the LED board stays ON.
- When the switch is released, the LED board stays ON and the LED indicator turns back to RED.

MAINTENANCE:

Caution: Always turn off AC power to the equipment before servicing. Servicing should be performed only by a qualified service technician. Use only MANUFACTURER supplied replacement parts.

BATTERY: The battery supplied with the Battery Backup model requires no maintenance. However, it should be tested periodically and replaced when it no longer operates the connected fixtures for the duration of a 30-second or 90-minute test. The battery supplied in this equipment has a life expectancy of 5 years when used in a normal ambient temperature of 72°F.

TESTING:

National Electric Code (NEC) and NFPA life safety code regulations require that routine tests need to be performed as listed below. Once every month, the unit needs to be tested for duration of 30 seconds. Push in hold the test switch to perform this test. Once every 12 months, a full 90 minute (per UL requirements) test needs to be performed on the unit. Disconnect power to the unit and leave it in the emergency mode. The LEDs should stay ON for at least 90 minutes.