



LED Important Safety Instructions

READ AND FOLLOW ALL SAFETY INSTRUCTIONS! SAVE THESE INSTRUCTIONS AND DELIVER TO OWNER AFTER INSTALLATION

- To reduce the risk of death, personal injury or property damage from fire, electric shock, falling parts, cuts/abrasions, and other hazards please read all warnings and instructions included with and on the fixture box and all fixture labels.
- Before installing, servicing, or performing routine maintenance upon this equipment, follow these general precautions.
- Installation and service of luminaires should be performed by a **qualified licensed electrician**.
- Maintenance of the luminaires should be performed by person(s) familiar with the luminaires' construction and operation and any hazards involved. Regular fixture maintenance programs are recommended.
- It will occasionally be necessary to clean the outside of the refractor/lens. Frequency of cleaning will depend on ambient dirt level and minimum light output which is acceptable to user. Refractor/lens should be washed in a solution of warm water and any mild, non-abrasive household detergent, rinsed with clean water and wiped dry. Should optical assembly become dirty on the inside, wipe refractor/lens and clean in above manner, replacing damaged gaskets as necessary.
- **DO NOT INSTALL DAMAGED PRODUCT!** This luminaire has been properly packed so that no parts should have been damaged during transit. Inspect to confirm. Any part damaged or broken during or after assembly should be replaced.
- **Recycle:** For information on how to recycle LED electronic products, please visit www.epa.gov.
- These instructions do not purport to cover all details or variations in equipment nor to provide every possible contingency to meet in connection with installation, operation, or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's or owner's purposes, this matter should be referred to Acuity Brands Lighting, Inc.



WARNING: RISK OF ELECTRIC SHOCK

- ✓ Disconnect or turn off power before installation or servicing.
- ✓ Verify that supply voltage is correct by comparing it with the luminaire label information.
- ✓ Make all electrical and grounded connections in accordance with the National Electrical Code (NEC) and any applicable local code requirements.
- ✓ All wiring connections should be capped with UL approved recognized wire connectors.



WARNING: RISK OF BURN

- ✓ Allow lamp/fixture to cool before handling. Do not touch enclosure or light source.
- ✓ Do not exceed maximum wattage marked on luminaire label.
- ✓ Follow all manufacturer's warnings, recommendations and restrictions for: driver type, burning position, mounting locations/methods, replacement and recycling.



CAUTION: RISK OF INJURY

- ✓ Wear gloves and safety glasses at all times when removing luminaire from carton, installing, servicing or performing maintenance.
- ✓ Avoid direct eye exposure to the light source while it is on.



CAUTION: RISK OF FIRE

- ✓ Keep combustible and other materials that can burn, away from lamp/lens.
- ✓ Do not operate in close proximity to persons, combustible materials or substances affected by heat or drying.

Always read the fixtures complete installation instructions prior to installation for any additional fixture specific warnings. Please see product specific installation instructions for additional warnings or any applicable FCC or other regulatory statements.

Failure to follow any of these instructions could void product warranties. For a complete listing of product Terms and Conditions, please visit www.acuitybrands.com.

LED Important Safety Instructions



CAUTION: RISK OF PRODUCT DAMAGE

- ✓ Never connect components under load.
- ✓ Do not mount or support these fixtures in a manner that can cut the outer jacket or damage wire insulation.
- ✓ Controls for dimming, auto-sensing, or remote control of a luminaire that are not factory-wired to the luminaire must be checked for compatibility with the luminaire prior to installation. LED fixtures must be powered directly off a switched circuit.
- ✓ Unless individual product specifications deem otherwise: Do not restrict fixture ventilation. Allow for some volume of airspace around fixture. Avoid covering LED fixtures with insulation, foam, or other material that will prevent convection or conduction cooling.
- ✓ Unless individual product specifications deem otherwise: Do not exceed fixtures maximum ambient temperature.
- ✓ Only use fixture in its intended location.
- ✓ LED products are Polarity Sensitive. Ensure proper Polarity before installation.
- ✓ Electrostatic Discharge (ESD): ESD can damage LED fixtures. Personal grounding equipment must be worn during all installation or servicing of the unit.
- ✓ Do not touch individual electrical components as this can cause ESD, shorten lamp life, or alter performance.
- ✓ Some components inside the fixture may not be serviceable. In the unlikely event your unit may require service, stop using the unit immediately and contact an ABL representative for assistance.
- ✓ Always read the fixtures complete installation instructions prior to installation for any additional fixture specific warnings.
- ✓ Always ensure that the electrical distribution system is up to NEC (and any applicable local code) requirements.
- ✓ Verify that power distribution system has proper grounding. Lack of proper earth ground can lead to fixture failure and may void warranty.

Choose either Part 15 OR Part 18 and move to Page 3 Installation Instructions under Delivery. Outdoor will always use Part 15.

All luminaires that contain electronic devices that generate frequencies above 9kHz from any component within the luminaire comply with Part 15 of the FCC Rules. Operation is subject to the following two conditions:

- (1) This device may not cause harmful interference
- (2) This device must accept any interference received, including interference that may cause undesired operation

This device complies with Part 18 of the FCC Rules but may cause interference with cordless and cell phones, radios, televisions, and other electronic devices. To correct the problem, move the device away from the luminaire or plug into a different outlet. This product may cause interference to radio equipment and should not be installed near maritime safety communications equipment or other critical navigation or communications equipment operating between 0.45-30MHz.

Always read the fixtures complete installation instructions prior to installation for any additional fixture specific warnings. Please see product specific installation instructions for additional warnings or any applicable FCC or other regulatory statements.

Failure to follow any of these instructions could void product warranties. For a complete listing of product Terms and Conditions, please visit www.acuitybrands.com.

Aculux®	Distech Controls™	Healthcare Lighting®	Juno®	nLight®
AEL®	DTL®	Holophane®	Lithonia Lighting®	Peerless®
aLight	eldoLED®	Hydrel®	Luminaire LED	Reloc®
Atrius®	Euerka	Indy™	Luminis®	Sensor Switch®
Cyclone	Gotham®	IOTA®	Mark Architectural Lighting™	Sunoptics®

Acuity Brands Lighting, Inc. assumes no responsibility for claims arising out of improper or careless installation or handling of its products.


Observe NOPB MRI

INSTALLATION INSTRUCTIONS


912-00659 REV. A 1/7/2026

A. General Identification..... Page 3
 B. Luminaire installation..... Pages 4 - 8
 C. Wiring Schematics..... Pages 9 – 11

A. General Identification of Observe NOPB luminaire(s):




NOPB MRI 2X4




NOPB MRI 2X2

General Identification of Observe NOPB Remote Driver Box(es):



**NOPB RMDG
(GRID)**



**NOPB RMDS
(SURFACE)**

!REMOTE DRIVER BOX – NOT RATED FOR INSULATION CONTACT!

PRIOR TO INSTALLATION

- Read and familiarize yourself with the nomenclature and instructions before starting installation.
- Turn off electricity at the breaker panel or fuse box and follow National Electrical Code regulations and applicable local building codes.

B. Installation:

****Caution:** MAKE SURE LUMINAIRE IS MOUNTED TO A SECURE STRUCTURE. USE APPROPRIATE MOUNTING HARDWARE TO INSTALL FIXTURE RATED FOR YOUR APPLICATION. FAILURE TO MOUNT FIXTURE CORRECTLY COULD RESULT IN SERIOUS INJURY.

***ABOVE CEILING ACCESS REQUIRED**

- RETAIN THESE INSTALLATION INSTRUCTIONS

LUMINAIRE –

1. Place the fixture in the appropriate T-Bar ceiling structure. Handle fixture by the frame. DO NOT PUSH ON LENS.
2. Bend the built in T-Bar clips to secure the fixture to the T-Bar ceiling or use hanger wire hole (see Figure 1). Secure T-Bar clips to the T-Bar ceiling with fasteners (not provided) as local codes dictate.
3. Remove 2X 8-32 fasteners to gain access to fixture wiring (see Figure 2). Fixture wiring is color coded to match terminal block label present in driver box. Ensure cover is re-installed following termination of conduit/connections. Max recommended remote mount distance is 25 feet (7.62 meters), 20ga min. (Conduit/Fittings/Remote wiring provided by-others)





FIGURE 1



!DO NOT PUSH ON LENS!

2X 8-32 FASTENERS




FIGURE 2

TOOLS REQUIRED FOR INSTALLATION (by others)


- Safety Glasses
- Protective Gloves
- Philips Screwdriver (No. 2)
- Wire Strippers

B. Installation cont.:

RMDG/S — remote mounted driver box

1. Locate remote driver box and install as local codes dictate. Max recommended remote mount distance is 25 feet (7.62 meters), 20ga min. Conduit/wiring provided by-others
2. Remove perforated driver box cover (see Figure 3) and remove KO plug. Make electrical connections. Factory provided wiring is color coded to match label in driver box. (see Figure 4) Re-install perforated driver box cover when wiring is complete.
3. Remove non-perforated driver box cover (see Figure 5) and make electrical connections from supply and dimming circuit if applicable (ZT). Properly ground as local codes dictate. Re-install non-perforated driver box cover when wiring is complete.

!Driver box contains ferrous materials and may not reside within MRI room!




!REMOTE DRIVER BOX – NOT RATED FOR INSULATION CONTACT!

B. Installation cont.:


Remote Wiring:

1. 2x2 Luminaire – If present connect RED and RED/WHITE leads together and BLACK and BLACK/WHITE leads together inside luminaire splice compartment. Combined leads to be terminated into corresponding “AMB” terminal. (see diagram below)
2. 2x4 Luminaire – All leads present are “wire for wire” to driver box terminals. (see diagram below)

ENSURE NON-FERROUS CONNECTORS ARE UTILIZED FOR ANY TERMINATION MADE WITHIN THE MRI SPACE!





B. Installation cont.: RMDG/S – remote mounted driver box



*IMAGE SHOWN REFLECTS DRIVER BOX FOR 2X4 EXAM/SKY LUMINAIRE, # OF CONNECTORS PRESENT MAY VARY BASED ON OPTIONS ORDERED, INSTALL PROCESS DOES NOT DIFFER

WIRING TO DRIVER(S) COORDINATED FROM FACTORY, NOT TO BE TOUCHED DURING INSTALL



FIXTURE WIRING IS COLOR CODED TO DRIVER BOX TERMINAL LABEL. EXTENSION/COORDINATION OF CONNECTION IS RESPONSIBILITY OF INSTALLING CONTRACTOR PER LOCAL CODE

FIGURE 4

B. Installation cont.: RMDG/S – remote mounted driver box





FIGURE 5

FILTER CHANNEL REQUIREMENTS: (FILTERS SOLD SEPARATELY)


NOMENCLATURE:	# OF CHANNELS
NOPB MRI 2X2 CLOUD (SKY ONLY)	2
NOPB MRI 2X2 NOSKY (STATIC ONLY)	1
NOPB MRI 2X2 STATIC + SKY	3
NOPB MRI 2X4 CLOUD (SKY ONLY)	4
NOPB MRI 2X4 NOSKY (STATIC ONLY)	2
NOPB MRI 2X4 STATIC + SKY	6

B. Installation cont.: RMDG/S – remote mounted driver box

RDMS DETAIL -





RDMG DETAIL -




C. Wiring Schematics:

ZT WIRING – !ALL INPUTS MUST BE FED FROM SAME BRANCH CIRCUIT!



ZT – SOME OPTIONS MAY HAVE ONLY (1) IC DETECTOR PRESENT, BASED ON NUMBER OF CIRCUITS


NLIGHT WIRING –



TYPICAL OF BOTH 2X2 AND 2X4 NLIGHT

C. Wiring Schematics cont.:

NLTAIR2 WIRING –



TYPICAL OF BOTH 2X2 AND 2X4 NLTAIR2